

Declaration of Performance No. DOP1010C

18.04.2016

MANUFACTURER:

Abloy Oy
Joensuu factory
 Wahlforssinkatu 20
 FI-80100 Joensuu
 FINLAND

System or systems of
 assessment and verification
 of constancy of
 performance of the
 construction product:
AVCP 1

NOTIFIED PRODUCT CERTIFICATION BODY:

**Warrington Certification
 Limited**
 ID No: 1121
 Holmesfield Road,
 Warrington
 Cheshire, WA1 2DS
 UK

Notified product certification
 body performed the
 determination of the
 product type on the basis of
 type testing (including
 sampling), initial inspection
 of the manufacturing plant
 and of the factory
 production control and
 continuous surveillance,
 assessment and evaluation
 of factory production control
 and issued the certificate of
 constancy of performance
 of the product.

No. **1121-CPR-AD5244**

PRODUCT AND DESCRIPTION

Type:
ABLOY DC335

Description:
 Controlled door closing devices (door closers)

Intended use:
 On fire and smoke compartmentation doors
 (to fulfil the self-closing requirements of such doors)

Arm:
 projecting arm, size EN3-5

Classification			EN1154:1996/ A1:2002 + AC:2006 Building hardware. Controlled door closing devices.
4.2 Category of use	4	for closing doors from 180°	
4.3 Number of test cycles	8	500 000 cycles	
4.4 Test door mass	3-5	power size adjustable	
4.5 Fire behaviour	1	Suitable for use on fire doors	
4.6 Safety	1	only grade 1 is identified	
4.7 Corrosion resistance	3	high resistance (96h)	

Joensuu 18.4.2016

On behalf of Abloy Oy, Door Control



signature

Antti Piitulainen
 Vice President